

Cc: Mills, Brian (Safety)[brian.mills@titan-intl.com]; Woodruff@dmww.com[Woodruff@dmww.com]; Jackson, Hylton [DNR][Hylton.Jackson@dnr.iowa.gov]
To: McCoy, Erin[McCoy.Erin@epa.gov]
From: Gts
Sent: Fri 8/19/2016 8:32:40 PM
Subject: Re: Dico Groundwater Extraction and Treatment System Not Running

Erin

From past experience (and I could be wrong) it is a part inside the electrical box, like a logic phase monitor unit

It happened once a few years back and Brian was with the electrical company engineer for over 4 hours

Hopefully Monday Seneca can fix it

Brian will let us know once the electricians find what is wrong

Sent from my iPhone

On Aug 19, 2016, at 4:29 PM, McCoy, Erin <McCoy.Erin@epa.gov> wrote:

Do we know how long it's been off line or the reason yet?

<image001.gif>Erin McCoy, P.G. | Remedial Project Manager

EPA Region 7 | Superfund Division | Iowa Nebraska Branch

11201 Renner Blvd | Lenexa, KS 66219

Phone: 913.551.7977

mccoy.erin@epa.gov | www.epa.gov

From: Mills, Brian (Safety) [mailto:brian.mills@titan-intl.com]

Sent: Friday, August 19, 2016 3:06 PM

To: McCoy, Erin <McCoy.Erin@epa.gov>; Woodruff@dmww.com; Jackson, Hylton [DNR] <Hylton.Jackson@dnr.iowa.gov>; Gazi George (gtsi2000@yahoo.com) <gtsi2000@yahoo.com>

Subject: Dico Groundwater Extraction and Treatment System Not Running

The groundwater extraction and treatment system at Dico is not running. There is power at the control panel, but the air stripping tower and extraction wells are not running.

A contractor is scheduled to be at Dico on Monday, August 22 at 9 AM to troubleshoot the system and get it operational again.

Brian Mills

Please Note: The information contained in this message may be privileged and confidential, protected from disclosure, and/or intended only for the use of the individual or entity named above. If the reader of this message is not the intended recipient, or an employee or agent responsible for delivering this message to the intended recipient, you are hereby notified that any disclosure, distribution, copying or other dissemination of this communication is strictly prohibited. If you received this communication in error, please immediately reply to the sender, delete the message and destroy all copies of it. Any views or opinions expressed in this message are solely those of the individual sender, except where the sender specifies with authority them to be the views of Titan. Titan reserves the right to monitor both incoming and outgoing e-mails and therefore the sender and recipient of such e-mails should have no expectation of privacy in this regard. Thank You.